



# पनवेल महानगरपालिका

ता. पनवेल, जि. रायगड, पिन नं. 410 206

कार्यालय :- 27458040/41/42  
अग्निशमन विभाग :- 27461500

ईमेल :- punevelcorporation@gmail.com  
फॅक्स नं :- 022-7452233

कार्यालय जी.क्र./पमपा/अग्निशमन/९३९/2021

दिनांक :- 18/03/2021

प्रति,  
महात्मा एड्युकेशन सोसायटी,  
प्लॉट न. १, सेक्टर ८,  
खांदा कॉलोनी, न्यू पनवेल.

विषय : पनवेल महानगर पालिका अग्निशमन विभागाकडे लायसन्स अधिकरण यांचे मार्फत ब प्रमाणपत्र सादर  
केले बाबत.

संदर्भ :

1. मेसर्स श्री सहुरुकृपा फायर सर्व्हिसेस प्रा.लि यांचे कडील ब प्रमाणपत्र दिनांक १०/०२/२०२१.
2. पनवेल महानगर पालिकेचा दिनांक ८ जुन २०१७ रोजीचा प्रशामकीय ठराव.
3. आपण पावती क्रमांक F104/8803 दिनांक 18/03/2021 अन्वये जमा केलेले वार्षिक शुल्क  
रक्कम रुपये 3,600/- (तीन हजार सहाशे फक्त)

महाराज,

उपरोक्त विषयानुरूप आपण कडून संदर्भ क्रमांक १ नुसार मेसर्स श्री सहुरुकृपा फायर सर्व्हिसेस प्रा.लि  
यांचे कडील महाराष्ट्र आग प्रतिबंधक व जीव सुरक्षाउपाययोजना २००६ या अग्निशमन कायद्यातील कलम ३  
(३) या तरतुदीनुसार ब प्रमाणपत्र सादर केलेले आहे. तसेच याच कायद्यातील कलम १३(१) नुसार आपणाकडून  
वार्षिक शुल्क देखील या विभागाने स्वीकारलेले आहे. अग्निशमन कायद्यामध्ये अग्निशमन विभागा मार्फत देण्यात  
आलेला ना-हरकत दाखला नूतनीकरण करण्याची कोणतीही तरतूद नाही.

प्रकरणी आपण श्री सहुरुकृपा फायर सर्व्हिसेस प्रा.लि यांचे कडील सादर केलेल्या "ब"  
प्रमाणपत्राची पोहोच पावती आपणास देण्यात येत आहे.

भविष्यात आपण प्रती ६ महिन्यांनी अग्निशमन कायद्यातील तरतुदीनुसार महाराष्ट्र शासना कडील  
मान्यताप्राप्त लायसन्स अधिकरनाकडील "ब" प्रमाणपत्र सादर करावे, अन्यथा या कायद्यातील तरतुदीनुसार  
आपणावर योग्य ती कारवाई प्रस्तावित करण्यात येईल.

मुख्य अग्निशमन अधिकारी  
पनवेल महानगर पालिका

प्रत (बांना) मेसर्स श्री सहुरुकृपा फायर सर्व्हिसेस प्रा.लि



**FORM 'B'**

**Section 3 (3) and Rule 4 (2)**

**Six Monthly Certificates to be given in e every January and July by the Owner  
or the Occupier for Compliance of the Fire Prevention and Life Safety  
Measures**

**CERTIFICATE**

Certified that We have carried out inspection of the Fire Prevention and life safety measures installed in the following Building or Premises namely :

**M/S Mahatma Education Society, Plot No.1 , Sector 8, Khanda Colony, Navi Mumbai.**

We further certify that these installations in the above mentioned building are maintained in good repair and efficient conditions during the period from January 2020 to June 2020 as required under the Provision of the Maharashtra Fire Prevention and Life Safety Measures Act 2006 ( Mah. III of 2007 ). The details of the inspection of installations carried by us are mentioned in the report appended herewith.

Place : Navi Mumbai

Signature and Address of the Licensed Agency

Date : 10/2/2021



*Signature*

License No. MFS - LA/RF - 109

License No. MFS - LA/RD - 229

**Annexure to Form 'B'**

List of Accessories Serviced & Maintain at **Mahatma Education Society.**

Plot No. 1 , Sector 8, Navi Mumbai.

**Sub:-** Installation Report of Fire Equipments installed at M/S Mahatma Education Society., ( G + 6 – 2 Wings & G + 7 -2 Wings )

S. No.	Description	Qty.
1	Vertical Risers 100 mm dia	4 No.
2	Hydrant Valves on each Floors	26 Nos.
3	Court-Yard Hydrant Valves	4 Nos.
4	Hose Rill Drums with Rubber Pipes/Nozzles on each Floors	26 Nos.
5	Hose Boxes on alternate Floors.	13 Nos.
6	C P Hose with M/F Couplings on alternate Floors.	13 Nos.
7	Short Branch Pipes with Nozzles.	13 Nos.
8	Main Fire Pump – 15 H P	2 Nos.
9	Jokey Pump – 7.5 H P	2 Nos.
10	Booster Pumps – 5 H P	4 Nos.
11	ABC Type Fire Extinguishers of 5 / 2K.G. Capacity	8 Nos.
12	Co2 Type Fire Extinguishers of 5 / 2K.G. Capacity	4 Nos.
13	Manual Call Points & Hooters / Panel	4 Set.
14	Inlet Unit	1 No.
15	Breaching Units	2 No.
16	G M Air release Valve	4 No.

Place: Navi Mumbai

Date : 10/2/2021

Yours Faithfully

For **Shree Sadguru Krupa Fire Services Pvt. Ltd.**



*Mhaik*  
Director